Victaulic Bolted Split-Sleeve Products (VBSP) Style 233S stainless steel restrained couplings (formerly Depend-O-Lok FxF Modified) provide a fully restrained, flexible pipe joint that satisfies the requirements set forth by the AWWA C227 Standard for Bolted, Split-Sleeve Restrained and Non-Restrained Couplings for Plain-End Pipe.

This style of coupling is typically used in buried or exposed pipe applications for field joint connections where joint flexibility and thrust restraint is required. Style 233S couplings are designed to allow for dynamic (in-service) joint deflection and are most commonly used in pairs outside of a structure to accommodate differential settlement between the structure and the pipeline. The Style 233S couplings can also allow for up to 1"/25 mm of axial pipe movement at the joint due to thermal pipe movement. Typical applications include water and wastewater treatment pipelines, ethanol and other chemical plant piping, pulp and paper industry piping, and other piping applications where corrosion resistant, flexible restrained joints are required.

The dual-arched mechanical coupling body houses the o-ring gaskets that provide a radial seal around the circumference of the pipe, while a sealing plate provides for the axial seal across the coupling body and pipe joint. The Style 233S coupling incorporates a restraint ring welded to each pipe end (furnished with the coupling), allowing the coupling housing to straddle the restraint rings and confining the rings under the coupling body in order to prevent joint separation. The coupling housing and restraint ring welds are designed to accommodate hoop stress and end loads to meet system pressure requirements. Style 233S restrained couplings also perform at negative pipe pressures up to full vacuum. The o-ring gasket is not pressure responsive and therefore does not require internal pipe pressure to assist with the seal. The arched cross-sectional design provides stiffness to resist forces encountered during negative pressure (submerged) or vacuum service.

Style 233S couplings are available in standard nominal sizes from 8 – 96"/200 – 2400 mm, with other sizes available based on design and application requirements. The Style 233S restrained coupling can accommodate operating pressures up to 300 psi/2065 kPa (with higher pressure available) depending on the actual pipe diameter and wall thickness. For pressures and sizes not shown in the dimension and performance tables contact Victaulic for information on our engineered products by visiting our web site.

All flexible mechanical couplings should be properly supported to minimize or eliminate undesirable loads at the joint. Pipe support requirements are defined within the Victaulic Application Guidelines document. Please see publication 26.20.

For proper closure tool selection see column marked Tool Type on pages 6-7.



8 - 96"/200 - 2400mm

JOB/OWNER

System No._____ Location _____

CONTRACTOR

Date

Submitted By _____

ENGINEER

Spec Sect _____ Para _____ Approved _____

Date_

ctaulic

60.08 1

www.victaulic.com

VICTAULIC IS A REGISTERED TRADEMARK OF VICTAULIC COMPANY. © 2013 VICTAULIC COMPANY. ALL RIGHTS RESERVED. REV_K

PRODUCT GUIDE


	Product Style Guide								
Submittal Number	Style Number	Coupling/Body Material	Application						
60.01	230	Carbon Steel	Non-Restrained Coupling						
60.02	230S	Stainless Steel	Non-Restrained Coupling						
60.03	231	Carbon Steel	Expansion Coupling						
60.04	231S	Stainless Steel	Expansion Coupling						
60.05	232	Carbon Steel	Restrained Coupling						
60.06	232S	Stainless Steel	Restrained Coupling						
60.07	233	Carbon Steel	Restrained Coupling For Dynamic Joint Deflection						
60.08	233S	Stainless Steel	Restrained Coupling For Dynamic Joint Deflection						
60.09	234	Carbon Steel	Restrained Single-Gasket Coupling						
60.10	234S	Stainless Steel	Restrained Single-Gasket Coupling						

SEGMENTED COUPLINGS

The Style 233S dimension tables list the minimum number of coupling housing segments for a particular pipe size. For special applications, restrained couplings are available in two (or more) segments to allow for installation of the coupling over an existing pipe joint or to facilitate ease of handling for larger size couplings. The o-ring gaskets (except Silicone) can be furnished "split" to allow for field bonding when an existing pipe joint configuration does not allow for installation of a complete o-ring onto the pipe end.

BODY TYPE Cross-Section

NOTE: Body type is not optional and will be determined by system requirements.



Type 2 coupling is a shouldered coupling. This is a heavy duty coupling to accommodate higher pressures for certain pipe diameters. The shoulders welded to the edge of the coupling body provide a vertical bearing surface for the restraint rings and provide additional cross-sectional stiffness. The limit rings on the inside of the coupling body ensure that any axial movement or dynamic joint deflection is distributed across the coupling between both sides of the joint.



www.victaulic.com VICTAULIC IS A REGISTERED TRADEMARK OF VICTAULIC COMPANY. © 2013 VICTAULIC COMPANY. ALL RIGHTS RESERVED. 60.08_2

COUPLING COMPONENTS

1. Body – Dual arch cross-section.


2. Shoulders – Provide additional stiffness, allow for larger o-ring gasket and provide vertical bearing surface for restraint rings.

3. Closure Plates – Low profile bolt pads for installation and tightening of coupling; gap between plates of installed coupling allows for field flexibility.

- 4. Sealing Plate Provides axial seal across the coupling body and pipe joint.
- 5. O-ring Gaskets Provide circumferential seal.
- 6. Fasteners
 - Studs High Strength Threaded Rod
 - Nuts Heavy Hex Nuts

Washers – SAE small pattern flat washers

7. Restraint Rings - Attached to pipe ends to create a restrained joint.



ONE SEGMENT HOUSING

TWO SEGMENT HOUSING



MATERIAL SPECIFICATIONS	Body Stainless Steel conforming to ASTM A240 316/316L
	Shoulders
	Stainless Steel conforming to ASTM A240 316L
	Closure Plates Stainless Steel conforming to 316L
	Sealing Plate Stainless Steel conforming to ASTM A240 316L
	O-ring Gaskets
	Standard (Specify choice on order):
	• EPDM -30°F to +230°F/-34°C to +110°C Cold and hot water within allowable temperature range; dilute acids; excellent resistance to the deteriorative effects of ozone, oxygen, heat and most chemicals not involving hydrocarbons. NOT RECOMMENDED FOR PETROLEUM SERVICES.
	• Silicone -30°F to +350°F/-34°C to +177°C Dry, hot air applications; excellent resistance to many chemicals. NOT RECOMMENDED FOR HOT WATER OR STEAM APPLICATIONS.
	 Isoprene -40°F to +160°F/-40°C to +71°C Water; salt water; sewage; good resistance to oxygen and dilute acids
	Services listed are general service recommendations only. Refer to a chemical elastomer guide for specific applications and suitability of gasket material for services that are not listed.
	 Optional gasket (specify choice on order): Nitrile -20°F to +180°F/-28°C to +82°C Water; petroleum products, vegetable and mineral oils; air with oil vapors within allowable temperature range; good resistance to hydrocarbons; acids and bases.
	• Fluouroelastomer +20°F to +300°F/-7°C to +149°C Outstanding resistance to heat and most chemicals.
	• Neoprene -30°F to +180°F/-34°C to +82°C Water and wastewater; good resistance to ozone, effects of UV and some oils.
	Restraint Rings
	Stainless Steel conforming to ASTM A276 316L
	Permanent Fasteners
	Studs - Stainless Steel conforming to ASTM A193 Grade B8M 316 Class 2
	Nuts - Heavy hex nuts Stainless Steel conforming to ASTM A194 Grade 8M 316
	Washers - Stainless Steel Type 316 SAE pattern
	Installation Fasteners (for installation purposes only)
	Studs - Carbon Steel conforming to ASTM A193 Grade B7 zinc plated
	Nuts - Heavy hex nuts Carbon Steel conforming to ASTM A194 Grade 2H zinc plated
	Washers - Carbon Steel SAE small pattern flat washers conforming to ASTM F436 SAE pattern zinc plated

ictaulic

REV_K


PIPE END DIMENSIONAL For specific pipe diameter tolerances, pipe ovality (roundness) requirements and minimum/maximum TOLERANCE AND OVALITY pipe diameter allowance, refer to the tables included in the Installation Manuals (below) and 26.20 Application Guidelines. I-233.S1 - Styles 233/233S Restrained Flexible Coupling For Dynamic Joint Deflection (Type 2, One-Segment)


> I-233.S2 - Styles 233/233S Restrained Flexible Coupling For Dynamic Joint Deflection (Type 2, Two-Segments)




60.08_5


DIMENSIONS





1-SEGMENT






	(1)	(2)	(3)	Coupling Dimensions		(4)		(5)		(6)	
	Nominal Pipe Size In./mm	Actual Pipe O.D. Range In./mm	Maximum Working Pressure psi/kPa	Body Thickness In.	Width (Z) In./mm	Min. No. of Coupling Segments	No. of Fasteners - Fastener Dimensions Dia. x Length In. x In.	Approximate Weight Each Lbs/Kg.	Body Type	Tool Type	
	8 200	7.00 - 8.88 177.8 - 225.6	300 2065	10 ga.	12.50 317.5	1	3 - ¾ x 6	45 20	2	B,C	
	10 250	9.00 - 10.88 228.6 - 276.4	250 1725	10 ga.	12.50 317.5	1	3 - ¾ x 6	49 22	2	B,C	
	12 300	11.00 - 12.88 279.4 - 327.2	250 1725	3⁄16	12.50 317.5	1	3 - ¾ x 6	62 28	2	B,C	
	14 350	13.00 - 14.88 330.2 - 378	250 1725	3⁄16	12.50 317.5	1	3 - ¾ x 6	69 31	2	B,C	
	16 400	15.00 - 16.88 381 - 428.8	250 1725	3⁄16	12.50 317.5	1	3 - ¾ x 6	78 35	2	B,C	
	18 450	17.00 - 18.88 431.8 - 479.6	200 1375	3⁄16	12.50 317.5	1	3 - ¾ x 6	85 39	2	B,C	
	20 500	19.00 - 21.88 482.6 - 555.8	200 1375	3⁄16	12.50 317.5	1	3 - ¾ x 6	92 42	2	B,C	
、 、	24	22.00 - 26.88	100 690	3⁄16	12.50 317.5	1	3 - ¾ x 6	109 49	2	B,C	
\int	600	558.8 - 682.8	200 1375	1⁄4	12.50 317.5	1	3 - ¾ x 6	145 66	2	С	
			100 690	3⁄16	12.50 317.5	1	3 - ¾ x 6	130 59	2	B,C	
/	30 750	27.00 - 32.88 685.8 - 835.2		150 1035	1⁄4	12.50 317.5	1	3 - ¾ x 6	175 79	2	С
			200 1375	3/8	12.50 317.5	2	6 - 7⁄8 x 8	343 156	2	С	
			100 690	3⁄16	12.50 317.5	1	3 - ¾ x 6	152 69	2	B,C	
	36	33.00 - 38.88	150 1035	1⁄4	12.50 317.5	1	3 - ¾ x 6	206 93	2	С	
	900	838.2 - 987.6	175 1200	3/8	12.50 317.5	2	6 - 7⁄8 x 8	393 178	2	С	
			200 1375	1/2	14.75 374.7	2	8 - 1 x 8	620 281	2	С	
			100 690	1/4	12.50 317.5	1	3 - ¾ x 6	236 107	2	С	
	42 1050	39.00 - 44.88 990.6 - 1140.0	150 1035	3/8	12.50 317.5	2	6 - % x 8	444 201	2	С	
			200 1375	1/2	14.75 374.7	2	8 - 1 x 8	699 317	2	С	
			50 345	1⁄4	12.50 317.5	1	3 - ¾ x 6	267 121	2	С	
	48 1200	45.00 - 50.88 1143.0 - 1292.4	100 690	3/8	12.50 317.5	2	6 - 7⁄8 x 8	494 224	2	С	
			150 1035	1/2	14.75 374.7	2	8 - 1 x 8	779 353	2	С	

Couplings must be used on pipe with a minimum wall thickness that meets the requirements of AWWA C220 for stainless steel pipe.
 For actual Pipe O.D. round down to the nearest 1/2* to determine proper coupling size required.

(3) For allowable test or transient pressure, the maximum working pressure may be increased to 1½ times the values shown.

(a) For anowable test or transient pressure, the maximum working pressure may be increased to 1% times the Values shown.
 (4) 1-segment couplings may be available as 2-segment couplings to allow for in-place pipe installations. Contact Victaulic for details.
 (5) Coupling weights are based on nominal pipe diameter and include all accessories. Weight may vary based on actual size of pipe.
 (6) Closure Tool Recommendations.*
 B = CTM-02 Large Manual Closure Tool
 C = CTH-01 10-Ton Hydraulic Closure Tool
 * For more details on closure tools refer to page 12.
 Note: The data in this table only applies when stainless steel couplings are being used on stainless steel pipe.

VICTAULIC IS A REGISTERED TRADEMARK OF VICTAULIC COMPANY. © 2013 VICTAULIC COMPANY. ALL RIGHTS RESERVED.





60.08_6

www.victaulic.com

Style 233S Restrained Flexible Coupling For Dynamic Joint Deflection

DIMENSIONS	(1)	(2)	(3)		limensions	(4)		(5)		
	Nominal Pipe Size In./mm	Actual Pipe O.D. Range In./mm	Maximum Working Pressure psi/kPa	Body Thickness In.	Width (Z) In./mm	Min. No. of Coupling Segments	No. of Fasteners - Fastener Dimensions Dia. x Length In. x In.	Approximate Weight Each Lbs/Kg.	Body Type	
			50 345	1⁄4	Width (Z) Min. N Coup Segm 12.50 317.5 1 12.50 317.5 2 14.75 374.7 2 12.50 317.5 2		3 - 7⁄8 x 8	319 145	2	
	54 1350	51.00 - 56.88 1295.4 - 1444.8	100 690	3⁄8		2	6 - 7⁄8 x 8	534 242	2	
			150 1035	1/2		2	8 - 1 x 8	858 389	2	
			50 345	1⁄4		2	6 - 7⁄8 x 8	394 179	2	
	60 1500	57.00 - 62.88 1447.8 - 1597.2	100 690	3⁄8		2	6 - 7⁄8 x 8	584 265	2	
┙ ╓╱┨┞┶╖			150 1035	1/2		2	8 - 1 x 8	938 425	2	
	66 63.00 - 68.88		50 345	3⁄8		2	6 - 7⁄8 x 8	622 282	2	
	1650	1600.2 - 1749.6	100 690	1/2		2	8 - 1 x 8	1000 454	2	
	72	69.00 - 74.88	50 345	3/8		2	6 - 7⁄8 x 8	673 305	2	
	1800	1752.6 - 1902.0	100 690	1/2		2	8 - 1 x 8	1080 490	2	
	78	75.00 - 80.88 1905.0 - 2054.4	50 345	3/8		2	6 - 7⁄8 x 8	712 323	2	
	1950		100 690	1/2		2	8 - 1 x 8	1159 526	2	
1-SEGMENT	84	81.00 - 86.88	50 345	3⁄8		2	6 - 7⁄8 x 8	763 346	2	
77	2100	2057.4 - 2206.8	100 690	1/2		2	8 - 1 x 8	1222 554	2	
	90	87.00 - 92.88	50 345	3/8		2	6 - 7⁄8 x 8	802 364	2	
	2250	2209.8 - 2359.2	100 690	1/2		2	8 - 1 x 8	1283 582	2	
	96	93.00 - 102.00	50 345	3/8		2	6 - 7⁄8 x 8	863 391	2	
	2400	2362.2 - 2590.8	75 515	1/2		2	8 - 1 x 8	1379 626	2	


Couplings must be used on pipe with a minimum wall thickness that meets the requirements of AWWA C220 for stainless steel pipe.
 For actual Pipe 0.D. round down to the nearest ¹/₄ to determine proper coupling size required.

(3) For allowable test or transient pressure, the maximum working pressure may be increased to 1½ times the values shown.
 (4) 1-segment couplings may be available as 2-segment couplings to allow for in-place pipe installations. Contact Victaulic for details.

(5) Coupling weights are based on nominal pipe diameter and include all accessories. Weight may vary based on actual size of pipe.
 (6) Closure Tool Recommendations:*

B= CTM-02 Large Manual Closure Tool C= CTH-01 10-Ton Hydraulic Closure Tool *For more details on closure tools refer to page 12.

Note: The data in this table only applies when stainless steel couplings are being used on stainless steel pipe.



 \bigcirc

C

ictaulic VICTAULIC IS A REGISTERED TRADEMARK OF VICTAULIC COMPANY. © 2013 VICTAULIC COMPANY. ALL RIGHTS RESERVED.

(6)

С С С С С С С С С C С С С

С С

С С С

60.08_7

www.victaulic.com

PERFORMANCE

		(1)			(2) (3)	(3) (4)	(5)
Nominal Pipe Size In./mm	Maximum Working Pressure psi/kPa Carbon Steel	Maximum Working Pressure psi/kPa Stainless Steel	Maximum Working Pressure psi/kPa Ductile Iron	Body Type	Pipe End Separation Min - Max In./mm	Max. Allow. Deflection Degrees	Max. Permissibl End Load Ibf/N
8 200	300 2065	300 2065	300 2065	2	0.50 - 1.50 12.7 - 38.1	4° 0'	15079 67075
10 250	250 1725	250 1725	250 1725	2	0.50 - 1.50 12.7 - 38.1	3° 30'	19634 87336
12 300	250 1725	250 1725	250 1725	2	0.50 - 1.50 12.7 - 38.1	3° 15'	28274 125769
14 350	250 1725	250 1725	250 1725	2	0.50 - 1.50 12.7 - 38.1	3° 0'	38484 171185
16 400	250 1725	250 1725	200 1375	2	0.50 - 1.50 12.7 - 38.1	3° 0'	50265 223590
18 450	200 1375	200 1375	175 1200	2	0.50 - 1.50 12.7 - 38.1	3° 0'	50893 226383
20 500	200 1375	200 1375	150 1035	2	0.50 - 1.50 12.7 - 38.1	2° 30'	62831 279486
24	100 690	100 690	100 690	2	0.50 - 1.50 12.7 - 38.1	2° 0'	45238 201229
600	200 1375	200 1375	200 1375	2	0.50 - 1.50 12.7 - 38.1	2° 0'	90477 402462
	100 690	100 690	100 690	2	0.50 - 1.50 12.7 - 38.1	1° 45'	70685 314423
30 750	150 1035	150 1035	150 1035	2	0.50 - 1.50 12.7 - 38.1	1° 45'	106028 471636
	200 1375	200 1375	150 1035	2	0.50 - 1.50 12.7 - 38.1	1° 45'	141371 628850
	100 690	100 690	100 690	2	0.50 - 1.50 12.7 - 38.1	1° 30'	101787 452771
36	150 1035	150 1035	125 860	2	0.50 - 1.50 12.7 - 38.1	1° 30'	152681 679159
900	175 1200	175 1200	125 860	2	0.50 - 1.50 12.7 - 38.1	1° 30'	178128 792353
	200 1375	200 1375	175 1200	2	1.00 -2.00 25.4 - 50.8	1° 30'	203575 905547
	100 690	100 690	100 690	2	0.50 - 1.50 12.7 - 38.1	1° 15'	138544 616274
42 1050	150 1035	150 1035	125 860	2	0.50 - 1.50 12.7 - 38.1	1° 15'	207816 924412
	200 1375	200 1375	150 1035	2	1.00 -2.00 25.4 - 50.8	1° 15'	277088
	50 345	50 345	50 345	2	0.50 - 1.50 12.7 - 38.1	1° 7'	90477 402462
48 1200	100	100	100 690	2	0.50 - 1.50 12.7 - 38.1	1° 7'	180955 804928
	150 1035	150 1035	125 860	2	1.00 -2.00 25.4 - 50.8	1° 7'	271433

For allowable test or transient pressure, the maximum working pressure may be increased to 1½ times the value shown.
 Maximum allowable axial pipe movement at the joint is the difference between the maximum and minimum pipe separation. At maximum pipe

end separation, axial movement can only occur via pipe expansion into the joint and vice versa. (3) Pipe end movement and deflection are non-concurrent.

(4) Published deflection values are intended and available for both static (installed) and dynamic (in-service) joint deflection. The coupling closure should be located 90 degrees from the direction of joint deflection.

(5) The maximum permissible end loads listed in the table are calculated using the nominal pipe O.D. The actual maximum permissible end load will be less or greater than the published figures depending on the actual pipe O.D.



PERFORMANCE

		(1)			(2) (3)	(3) (4)	(5)
Nominal Pipe Size In./mm	Maximum Working Pressure psi/kPa Carbon Steel	Maximum Working Pressure psi/kPa Stainless Steel	Maximum Working Pressure psi/kPa Ductile Iron	Body Type	Pipe End Separation Min - Max In./mm	Max. Allow. Deflection Degrees	Max. Permissible End Load Ibf/N
	50 345	50 345	50 345	2	0.50 - 1.50 12.7 - 38.1	1° 0'	114511 509370
54 1350	100 690	100 690	75 515	2	0.50 - 1.50 12.7 - 38.1	1° 0'	229022 1018741
	150 1035	150 1035	125 860	2	1.00 -2.00 25.4 - 50.8	1° 0'	343533 1528111
	50 345	50 345	50 345	2	0.50 - 1.50 12.7 - 38.1	0° 54'	141371 628850
60 1500	100 690	100 690	75 1035	2	0.50 - 1.50 12.7 - 38.1	0° 54'	282743 1257704
	150 1035	150 1035	100 690	2	1.00 -2.00 25.4 - 50.8	0° 54'	424115 1886558
66	50 345	50 345	50 345	2	0.50 - 1.50 12.7 - 38.1	0° 49'	171059 760908
1650	100 690	100 690	100 690	2	1.00 -2.00 25.4 - 50.8	0° 49'	342119 1521821
72	50 345	50 345	50 345	2	0.50 - 1.50 12.7 - 38.1	0° 45'	203575 905547
1800	100 690	100 690	100 690	2	1.00 -2.00 25.4 - 50.8	0° 45'	407150 1811094
78	50 345	50 345	50 345	2	0.50 - 1.50 12.7 - 38.1	0° 42'	238918 1062760
1950	100 690	100 690	75 515	2	1.00 -2.00 25.4 - 50.8	0° 42'	407150 1811094
84	50 345	50 345	50 345	2	0.50 - 1.50 12.7 - 38.1	0° 39'	277088 1232549
2100	100 690	100 690	75 515	2	1.00 -2.00 25.4 - 50.8	0° 39'	554176 2465098
90	50 345	50 345	50 345	2	0.50 - 1.50 12.7 - 38.1	0° 36'	318086 1414917
2250	100 690	100 690	75 515	2	1.00 -2.00 25.4 - 50.8	0° 36'	636172 2829834
96	50 345	50 345	50 345	2	0.50 - 1.50 12.7 - 38.1	0° 33'	361911 1609860
2400	75 515	75 515	50 345	2	1.00 -2.00 25.4 - 50.8	0° 33'	542867 2414793

(1) For allowable test or transient pressure, the maximum working pressure may be increased to 1½ times the value shown. (2) Maximum allowable axial pipe movement at the joint is the difference between the maximum and minimum pipe separation. At maximum pipe end separation, axial movement can only occur via pipe expansion into the joint and vice versa.

(3) Pipe end movement and deflection are non-concurrent.(4) Published deflection values are intended and available for both static (installed) and dynamic (in-service) joint deflection. The coupling closure should be located 90 degrees from the direction of joint deflection. (5) The maximum permissible end loads listed in the table are calculated using the nominal pipe O.D. The actual maximum permissible end load

will be less or greater than the published figures depending on the actual pipe O.D.



60.08

www.victaulic.com VICTAULIC IS A REGISTERED TRADEMARK OF VICTAULIC COMPANY. © 2013 VICTAULIC COMPANY. ALL RIGHTS RESERVED. **REV_K**

RESTRAINT RINGS Type 2 - Restraint Ring Location S(E) Pipe End E S Restraint Ring Single Flare Bevel Groove Weld Detail Back Weld - Must not d extend past the back (F) edge of the restraint ring s E Pipe End Restraint Ring Double Flare Bevel Groove Weld Detail

					Restraint Ring	
	(1)	(2)			(3)	(4)
Nominal Pipe Size In./mm	Maximum Working Pressure psi/kPa	Body Type	Width (Z) In./mm	Diameter (d) In.	Location (L) In./mm	Weld Size (E) In.
8 200	300 2065	2	12.50 317.5	1/4	4.00 101.6	3/32
10 250	250 1725	2	12.50 317.5	1/4	4.00 101.6	3/32
12 300	250 1725	2	12.50 317.5	1/4	4.00 101.6	3/32
14 350	250 1725	2	12.50 317.5	1/4	4.00 101.6	3/32
16 400	250 1725	2	12.50 317.5	1/4	4.00 101.6	3/32
18 450	200 1375	2	12.50 317.5	1/4	4.00 101.6	3/32
20 500	200 1375	2	12.50 317.5	1/4	4.00 101.6	3/32
24	100 690	2	12.50 317.5	1/4	4.00 101.6	3/32
600	200 1375	2	12.50 317.5	3/8	3.88 98.4	1/8
	100 690	2	12.50 317.5	1/4	4.00 101.6	3/32
30 750	150 1035	2	12.50 317.5	3/8	3.88 98.4	1/8
	200 1375	2	12.50 317.5	3/8	3.88 98.4	1/8
	100 690	2	12.50 317.5	1/4	4.00 101.6	3/32
36	150 1035	2	12.50 317.5	3/8	3.88 98.4	1/8
900	175 1200	2	12.50 317.5	3/8	3.88 98.4	1/8
	200 1375	2	14.75 374.7	1/2	4.38 111.1	5/32
	100 690	2	12.50 317.5	3/8	3.88 98.4	1/8
42 1050	150 1035	2	12.50 317.5	3/8	3.88 98.4	1/8
	200 1375	2	14.75 374.7	1/2	4.38 111.1	5/32
	50 345	2	12.50 317.5	3/8	3.88 98.4	1/8
48 1200	100 690	2	12.50 317.5	3/8	3.88 98.4	1/8
	150 1035	2	14.75 374.7	1/2	4.38 111.1	5/32

(1) For allowable test or transient pressure, the maximum working pressure may be increased to 11/2 times the values shown. (2) For applications other than air or gas, where a liquid or other medium is flowing through pipe, restraint ring weld

requirements are as follows:

Type 2 couplings require a full circumferential double flare bevel groove weld based on the weld sizes shown in the table. For low pressure air or gas applications, where the weight of the medium flowing through the pipe is not a consideration, a single flare bevel groove weld and/or less than a full circumference of weld may be allowed to attach the restraint rings. Contact Victaulic for specific details. Each restraint ring shipment includes restraint ring placement and welding data that is specific to application or project requirements. (3) Restraint rings must be welded perpendicular to the pipe axis with a tolerance of $L\pm \frac{1}{3}$ /1.6 mm.


(4) Flare bevel groove weld size in table is the minimum requirement. Depth of preparation S = (d) ÷ 2; Weld size E ≈ S * 0.625 per AWS D1.1. For a double flare bevel groove weld, the weld on the back side of the restraint ring must not extend beyond the outermost edge of the ring. The coupling shoulder must have unre stricted contact with the ring and the pipe O.D.

Note: The data in this table only applies when stainless steel couplings are being used on stainless steel pipe.

ctaulic

REV_K

RESTRAINT RINGS



					Restraint Ring	
	(1)	(2)			(3)	(4)
Nominal Pipe Size In./mm	Maximum Working Pressure psi/kPa	Body Type	Width (Z) In./mm	Diameter (d) In.	Location (L) In./mm	Weld Size (E) In.
	50 345	2	12.50 317.5	3/8	3.88 98.4	1/8
54 1350	100 690	2	12.50 317.5	3/8	3.88 98.4	1⁄8
	150 1035	2	14.75 374.7	1/2	4.38 111.1	5/32
	50 345	2	12.50 317.5	3/8	3.88 98.4	1/8
60 1500	100 690	2	12.50 317.5	3/8	3.88 98.4	1/8
	150 1035	2	14.75 374.7	1/2	4.38 111.1	5/32
66	50 345	2	12.50 317.5	3/8	3.88 98.4	1/8
1650	100 690	2	14.75 374.7	1/2	4.38 111.1	5/32
72	50 345	2	12.50 317.5	3/8	3.88 98.4	1/8
1800	100 690	2	14.75 374.7	1/2	4.38 111.1	5/32
78	50 345	2	12.50 317.5	3/8	3.88 98.4	1⁄8
1950	100 690	2	14.75 374.7	1/2	4.38 111.1	5/32
84	50 345	2	12.50 317.5	3/8	3.88 98.4	1/8
2100	100 690	2	14.75 374.7	1/2	4.38 111.1	5/32
90	50 345	2	12.50 317.5	3/8	3.88 98.4	1/8
2250	100 690	2	14.75 374.7	1/2	4.38 111.1	5/32
96	50 345	2	12.50 317.5	3/8	3.88 98.4	1/8
2400	75 515	2	14.75 374.7	1/2	4.38 111.1	5/32

(1) For allowable test or transient pressure, the maximum working pressure may be increased to 1% times the values shown.

(2) For applications other than air or gas, where a liquid or other medium is flowing through pipe, restraint ring weld requirements are as follows: Type 2 couplings require a full circumferential double flare bevel groove weld based on the weld sizes shown in

the table. For low pressure air or gas applications, where the weight of the medium flowing through the pipe is not a consideration, a single flare bevel groove weld and/or less than a full circumference of weld may be allowed to attach the restraint rings. Contact Victaulic for specific details. Each restraint ring shipment includes restraint ring placement and welding data that is specific to application or project requirements.

(3) Restraint rings must be welded perpendicular to the pipe axis with a tolerance of L± ½s⁴/1.6 mm.
(4) Flare bevel groove weld size in table is the minimum requirement. Depth of preparation S = (d) ÷ 2; Weld size E ≈ S * 0.625 per AWS D1.1. For a double flare bevel groove weld, the weld on the back side of the restraint ring must not extend beyond the outermost edge of the ring. The coupling shoulder must have unre-stricted contact with the ring and the pipe O.D.

Note: The data in this table only applies when stainless steel couplings are being used on stainless steel pipe.



CLOSURE TOOLS

Style 233S Restrained Flexible Coupling For Dynamic Joint Deflection



HYDRAULIC TOOL

Manual Tools

- CTM-01: for use on 5" and 8" body widths
- CTM-02: for use on 10" body widths
 - for use on 12" body widths with thickness of $\frac{3}{16}$ " or less
- CTH-01*: for use on 12" body widths with thickness of 1/4" or greater for use on 14", 16" and 18" body widths
- CTH-02: for use on all type 3 couplings
- Hydraulic tool package comes standard with:
 - one (1) tool head
 - one (1) hydraulic cylinder
 - one (1) hydraulic hose
 - one (1) hand pump

* A CTH-01 hydraulic closure tool can be used in applications where the CTM-02 manual closure tool is recommended.

Note: The closure tools listed above are designed specifically for Victaulic Style 230, 231, 232 and 233 couplings. If ordering custom product, contact Victaulic for appropriate tool



PRODUCT CONFIGURATOR

	C 0233 0096 50 X 2 C E O X X0											
Class	Style		ipe O.D. * Fraction	Body Type	Segments	PSI/kPa Rating	Rubber Compound	Paint	Hardware	Ring and Pipe Material		
С	0233	0007 through 0102	00 - 0 13 - 1/8 25 - 1/4 38 - 3/8 50 - 1/2 63 - 5/8 75 - 3/4 88 - 7/8	X – Stainless	1 – One 2 – Two	$\begin{array}{l} B - 50/345\\ C - 75/515\\ D - 100/690\\ E - 125/860\\ F - 150/1035\\ G - 175/1200\\ H - 200/1375\\ J - 250/1725\\ K - 300/2065\\ \end{array}$	E – EPDM I – Isoprene L – Silicone T – Nitrile V – Neoprene O – Fluoro- elastomer	0 – None	X – Stainless	XO – Stainless Steel Ring on Stainless Stee Pipe SO – Carbon Steel Ring on Carbon Steel Pipe DO – Carbon Steel Ring on Ductile Iron Pipe		

^ Couplings are available in a range of nominal sizes from 8 – 96".

* For actual pipe O.D. round down to the nearest 1/8" to determine proper coupling size required.

ENGINEERED PRODUCTS For non-standard products the Victaulic Engineered Products group can assist with specialty OPTIONS joints designed to meet the specific size, pressure and temperature requirements of your system. WARRANTY Refer to the Warranty section of the current Price List or contact Victaulic for details. NOTE This product shall be manufactured by Victaulic or to Victaulic specifications. All products to be installed in accordance with current Victaulic installation/assembly instructions. Victaulic reserves the right to change product specifications, designs and standard equipment without notice and without incurring obligations. TESTING Victaulic Style 233S couplings are designed to allow for a 50 percent increase over the published maximum working pressure for test and/or transient pressures. Due to the huge volume of air that can be involved in jobsite air testing and the nature of air or gas that is pressurized, jobsite air testing should be limited to 25 psi/175 kPa or less. Victaulic offers a dished head assembly prepared with a restraint ring for the Style 233S coupling for field testing a section of pipeline or to end a pipeline and allow for future expansion. Contact Victaulic for details.

