

# CLASSIFICATION OF PROPERTIES

## No B/MLTB-563-2012





for Initial Type Testing (ITT) consistent with the norm PN-EN 14351-1+A1:2010

Notified body NB 2189

Company: **ZAKŁADY PRODUKCYJNO-USŁUGOWE**  
**Kazimierz Janik DECCO POLSKA**  
 ul. V Poprzeczna 15, 04-611 Warszawa

Product: Windows and balcony doors made from PVC-U profiles of  
**THERMICCO**

Test results are included in the following test reports registered under the number of the request : MLTB-563-2012-A, -B, -C, -D;  
 MLTB-563.0-2012



Testing methods

Air permeability  
PN-EN 1026

Waterproofness  
PN-EN 1027

Wind load resistance  
PN-EN 12211

Security equipment  
capacity  
PN-EN 14609

Classification standards:	PN-EN 12207	PN-EN 12208	PN-EN 12210	Threshold value
 950 x 2300	<b>4</b>	<b>E750</b>	<b>C 4</b>	<b>350N</b>
 1701 x 2300	<b>3</b>	<b>8A</b>	<b>C 2 / B 3</b>	
 2500 x 1700			<b>C 5</b>	
 1465 x 1435	<b>4</b>	<b>9A</b>	<b>C 5</b>	
 2300 x 2500	<b>4</b>	<b>8A</b>	<b>C 4</b>	

Remarks: Enveloped hardware: ROTO NT.

**MOBILNE LTB**

Head of laboratory *Adam Mścichowski*

Świebodzice, 16-01-2012



**MOBILNE**  
 Laboratorium Techniki Budowlanej s.c.  
 Anna Mścichowska, Adam Mścichowski  
 58-300 Wałbrzych, ul. Jana Kasprwicza 21 lok.2  
 tel. 0 696 050 073, fax 074 661 41 40  
 NIP 8862868350, Regon: 020573602




MOBILNE LTB s.c.  
 A. Mścichowska, A. Mścichowski  
 NIP PL 8862868350  
 REGON 020573602

58-300 Wałbrzych, ul. Jana Kasprwicza 21 lok. 2  
 tel.: +48 74 854 51 12, fax: + 48 74 6614140  
<http://www.badaniaokien.pl>  
 e-mail: biuro@badaniaokien.pl

Notyfikowana jednostka  
 (notified body) NB 2189

# CLASSIFICATION OF PROPERTIES

## No B/MLTB-605-2012




for Initial Type Testing (ITT) consistent with the norm PN-EN 14351-1+A1:2010

Notified body NB 2189

Company **ZAKŁADY PRODUKCYJNO-USŁUGOWE**  
**Kazimierz Janik DECCO POLSKA**  
 ul. V Poprzeczna 15, 04-611 Warszawa

Product: External doors made from PVC-U profiles of  
**THERMICCO**

Test results are included in the following test reports registered under the number of the request : MLTB-605-2012




Air permeability  
PN-EN 1026



Waterproofness  
PN-EN 1027



Wind load resistance  
PN-EN 12211



Security equipment  
capacity  
PN-EN 14609

Testing methods

Classification standards:	PN-EN 12207	PN-EN 12208	PN-EN 12210	Threshold value
<p>1099 x 2300</p>	<b>3</b>	<b>3A</b> <b>3B</b>	<b>C 3</b>	<b>Npd.</b>
<p>2001 x 2252</p>	<b>3</b>	<b>4A</b> <b>5B</b>	<b>C 3</b>	

Remarks : **Npd.** performance not available due to lack of safety devices . Hinges : Dr Hahn, , insert : Wilka, lock : Winkhaus.

**MOBILNE LTB**

Head of laboratory *Adam Mścichowski*

Świebodzice, 05-03-2012



**MOBILNE**  
 Laboratorium Techniki Budowlanej s.c.  
 Anna Mścichowska, Adam Mścichowski  
 58-300 Wałbrzych, ul. Jana Kasprowicza 21 lok.2  
 tel. 0 696 050 073, fax 074 661 41 40  
 NIP 8862868350, Regon: 020573602



MOBILNE LTB s.c.  
 A. Mścichowska, A. Mścichowski  
 NIP PL 8862868350  
 REGON 020573602

58-300 Wałbrzych, ul. Jana Kasprowicza 21 lok. 2  
 tel.: +48 74 854 51 12, fax: + 48 74 6614140  
<http://www.badaniaokien.pl>  
 e-mail: [biuro@badaniaokien.pl](mailto:biuro@badaniaokien.pl)

Notyfikowana jednostka  
 (notified body) NB 2189